

Message

From: Toffel, Melissa [/O=EXCHANGELABS/OU=EXCHANGE ADMINISTRATIVE GROUP (FYDIBOHF23SPDLT)/CN=RECIPIENTS/CN=648B455AF7334836AD8A8F4BDC4126B2-MTOFFEL]
Sent: 8/21/2018 1:23:23 PM
To: Tim Miller [tmiller@nationalpremiumbeer.com]
Subject: RE: Easton Point follow-up questions to EPA's inspection on 6/13/18

Tim, for the two "Fail" results from the Veeder Root that were given for Tank 3 (the on road diesel) in a row, dated 2/20/17 and 2/27/17 – did you report that to MDE and what was done to investigate the failures? Do you have any paperwork to show that the Fails were investigated?



Melissa Toffel
U.S. EPA Region III
Land & Chemicals Division
RCRA Underground Storage Tank Branch
1650 Arch Street (Mail Code 3LC31)
Philadelphia, PA 19103
P: 215-814-2060
F: 215-814-3163



From: Tim Miller [mailto:tmiller@nationalpremiumbeer.com]
Sent: Wednesday, August 08, 2018 5:12 PM
To: Toffel, Melissa <Toffel.Melissa@epa.gov>
Subject: Re: Easton Point follow-up questions to EPA's inspection on 6/13/18



Tim Miller
Owner, National Premium Beer
Phone: 410-310-3553
Email: tmiller@nationalpremiumbeer.com
Website: NATIONALPREMIUMBEER.COM



Get your own  email signature

On Wed, Aug 8, 2018 at 2:13 PM, Toffel, Melissa <Toffel.Melissa@epa.gov> wrote:

EPA considers "Passes" and "Fails" as valid release detection results. "Invalids" are not sufficient.

Melissa Toffel
U.S. EPA Region III
Land & Chemicals Division

RCRA Underground Storage Tank Branch

1650 Arch Street (Mail Code 3LC31)

Philadelphia, PA 19103

P: 215-814-2060

F: 215-814-3163




From: Tim Miller [mailto:tmiller@nationalpremiumbeer.com]

Sent: Wednesday, August 08, 2018 2:11 PM

To: Toffel, Melissa <Toffel.Melissa@epa.gov>

Subject: Re: Easton Point follow-up questions to EPA's inspection on 6/13/18

OK, I am just looking for passing tests.



Tim Miller





Owner, National Premium Beer

Phone: 410-310-3553

Email: tmiller@nationalpremiumbeer.com

Website: NATIONALPREMIUMBEER.COM

.....



Get your own email signature

On Wed, Aug 8, 2018 at 1:23 PM, Toffel, Melissa <Toffel.Melissa@epa.gov> wrote:

Yes, going back as far as you have it... anything from January 2014 to the present.

Melissa Toffel

U.S. EPA Region III

Land & Chemicals Division

RCRA Underground Storage Tank Branch

1650 Arch Street (Mail Code 3LC31)

Philadelphia, PA 19103

P: 215-814-2060

F: 215-814-3163


From: Tim Miller [mailto:tmiller@nationalpremiumbeer.com]

Sent: Wednesday, August 08, 2018 1:16 PM

To: Toffel, Melissa <Toffel.Melissa@epa.gov>

Subject: Re: Easton Point follow-up questions to EPA's inspection on 6/13/18

So do you want the leak tests from the veeder root?



Tim Miller



Owner, National Premium Beer

Phone: 410-310-3553

Email: tmiller@nationalpremiumbeer.com

Website: NATIONALPREMIUMBEER.COM

.....



Get your own email signature

On Tue, Jul 24, 2018 at 9:54 AM, Toffel, Melissa <Toffel.Melissa@epa.gov> wrote:

Tim, I am able to offer up to a two-week extension to answer the questions, and since you have a vacation coming up it sounds like you will need it. If we make the new deadline August 17th, will you be able to provide me everything requested by then?

Melissa Toffel

U.S. EPA Region III

Land & Chemicals Division

RCRA Underground Storage Tank Branch

1650 Arch Street (Mail Code 3LC31)

Philadelphia, PA 19103

P: 215-814-2060

F: 215-814-3163

From: Tim Miller [mailto:tmiller@nationalpremiumbeer.com]

Sent: Tuesday, July 24, 2018 9:47 AM

To: Toffel, Melissa <Toffel.Melissa@epa.gov>


Subject: Re: Easton Point follow-up questions to EPA's inspection on 6/13/18

1. I will get you everything I have.
2. I will look but I think that is all I have.
3. I will look but I think that is all I have.
4. OK

5. I will look but I think that is all I have.



My best guess is that I took back over August 1,2016 but I will look for an exact date.

I am going away for a week starting 7/28/2018,fyi.



Tim Miller
Owner, National Premium Beer
Phone: 410-310-3553
Email: tmiller@nationalpremiumbeer.com
Website: NATIONALPREMIUMBEER.COM

.....
.....
.....



Get your own email signature

On Thu, Jul 12, 2018 at 2:46 PM, Toffel, Melissa <Toffel.Melissa@epa.gov> wrote:

Hi Tim – now that I’ve had time to write up my report and look at what info was provided during the inspection, as I had mentioned I do have follow-up questions for you. You had said that you had taken over operating the facility about a year and a half ago. Can you please provide **an exact date** that you took back over? This will be important in that the information I am requesting below will need to be provided going back to when you resumed operating the facility.

1. Please provide monthly tank release detection records for all five tanks going back to when you resumed operating the facility up through April 2018.
2. Provide annual functionality testing documentation of the line leak detectors for each tank, going back to when you resumed operation at the facility. I already have testing dated 6/27/16 and 3/23/18, but if you have any others please provide them.
3. Provide line tightness testing documentation for each tank, going back to when you resumed operation at the facility. I already have testing dated 6/27/16 and 3/23/18, but if you have any others please provide them.
4. Overfill could not be verified in the field, but it was mentioned that you may be utilizing ballfloats for each tank. Please provide verification from a third party that overfill is installed and functioning. If in fact ballfloats are being utilized, please provide a picture of each ballfloat lying next to its adjacent fillport.
5. I reviewed cathodic protection testing dated 6/17/16, 2/1/18, and 3/8/18 – do you have any others to provide since you resumed operation at the site?

Please submit this information by August 3, 2018. If you will have trouble meeting this timeframe, please give me a call to discuss. Thank you,

Melissa Toffel

U.S. EPA Region III

Land & Chemicals Division

RCRA Underground Storage Tank Branch

1650 Arch Street (Mail Code 3LC31)

Philadelphia, PA 19103

P: 215-814-2060

F: 215-814-3163